

**STATE OF OHIO  
ADJUTANT GENERAL'S DEPARTMENT  
2825 West Dublin Granville Road  
Columbus, Ohio 43235-2789**

AGOH-HRO

14 October 2009

MEMORANDUM FOR RECORD

SUBJECT: Minutes, Maintenance Facilities Safety Sub-Working Group.

1. Reference meeting 13 August 2009.
2. Attendance: COL McHenry (ILO the COS), LTC Wirth (SMO), LTC Hess (HRO), MAJ Mikula (Safety), LTC Henderson (ACOS), CPT McLoughlin (DIMR-Environmental), Mr. Justin Willie (Union Rep), 1LT Daryl Scott (HRO)
3. Review of priority RAC abatement tracking.
  - FMS 9 and FMS 11, Vacuums were tested and received PMCS. They still indicated that they were performing below standards. Industrial hygiene (IH) was sent to test the vacuums and they passed. IH needs to go to Piketon to re-test those machines.
  - FMS 16, Walbridge, has an improperly wired 220V receptacle and an ungrounded outlet. All are properly mitigated. A request is in contracting to hire an electrician to correct the issues.
  - CSMS/DSCC, water is still pooling by the bay door. Concrete work is required to resolve this issue.
  - Ravenna, the rappelling tower needs lightning protection. Installation of lightning rods is planned.
  - St. Mary's armory, has RAC 1 and RAC 2 hazards with electrical wiring. All are mitigated and the expected completion date of the repairs is 23 October.
  - Springfield armory, has RAC 1 and RAC 2 hazards with a leaky pipe and electrical wiring. All are mitigated and the expected completion date of the repairs is 16 October.
4. Environmental Findings.
  - No findings for this time period.
  - Expecting to have findings at the end of December; within 90 days.
5. Labor requested copy of RAC Abatement Tracking document prior to sub-working group meetings.
6. Next meeting is scheduled for 12 November at 1300.

DARYL G. SCOTT  
1LT, AG, OHARNG  
Labor Relations Specialist